

**PUBLIC WORKS DEPARTMENT
MONTHLY REPORT
June 2019**

ROADS	<ul style="list-style-type: none">• Grade all roads and repair washouts due to heavy rain• Patching holes on our roads• Removing beaver dams that hold back water and flooding our roads• Sweeper came this week and swept all our streets• Half load signs removed off our roads except Wilson/ Tonomo roads due to flooding and still wet on edges of road.• Road patrols and cutting trees off edges of roads is on going
WATER & SEWER	<ul style="list-style-type: none">• Public works repaired a few water and sewer shuts in TN and TS• Public Works changed 5 grinder pumps, and also completed some grinder pump repairs.• Maps were completed and installed in our Water/Sewer plants• PW picked up Sewer tank at Parkwood lane residence and returned to our shop• Half power (1 phase) in Temagami south caused a starter to fail on one of our pumps at Temagami Shores pumping station . we had it replaced and everything is working fine again• OCWA noticed a leak in a pipe at the Temagami South tower , PW and OCWA checked it out but we think it was coming from the top of the pipe somewhere. PW and OCWA are going to get a quote from Landmark to inspect both our towers because it been approximately 6 years since the last inspection was completed. PW will keep everyone updated• All docks have been installed and hooked up to break walls• Clean up at rabbit lake completed and back wall holding tree's and material up was replaced with Ballast.

<p>EQUIPMENT</p>	<ul style="list-style-type: none"> • T11- 2011 half ton had rad replaced and will need to replace ball joints on the front end by the fall of this year • 2009 ¾ ton truck needs severe box repairs due to age and rotting cross members on the box • Maintenance on Equipment • T-3 is all painted up and looks good , just missing a plastic piece on the fender and everything is completed from the accident. Waiting for part. • Welded bottom of floor on Garbage Truck Compactor due to wearing and age. This unit is showing signs of fatigue. Unit is a 1995.
<p>WASTE MANAGEMENT</p>	<ul style="list-style-type: none"> • Strathy Landfill – pushed domestic and wood waste • Haul fridges from Sisk to Strathy compound • Cleaned up all dumps but will be renting excavator for bailing holes for summer rush. • Landfill monitoring samples at all landfills were completed and awaiting results
<p>BUILDINGS</p>	<ul style="list-style-type: none"> • Unplugged toilets at municipal office and made minor repairs • Replaced water Valves and hose reel at the Temagami Ambulance building. Repaired eyewash station. PW will clean out both floor drains when time permits.
<p>PARKS & REC</p>	<ul style="list-style-type: none"> • Staff cleaned and prepared both fields for Base Ball tournament , they also cleaned and had everything completed for arena that weekend as well. Staff worked on weekend as well. Kubota was started and used to drag fields and pick up garbage. • Removed , releveled and replaced bleachers at TN park • Back bladed and Leveled out TN beach sand , also cleaned up wood and garbage from winter. • Cleaned up at the tower and found 2 of our benches from the lookout were thrown over and are in pieces at the bottom of the lookout. They also threw our swing over the railing but because

	<p>it was changed to a tree there was minimal damage and we can repair the parts that are broken. It has been reported to the police but have not heard back from them yet</p> <ul style="list-style-type: none"> • PW temporarily repaired 4 steps at the tower, steps should be replaced • Repaired handicap ramp to tower, flower beds should be replaced at bottom of tower whenever time permits
CAPITAL PROJECTS (2019)	<ul style="list-style-type: none"> • RFP for Granular 'M' gravel for our roads was sent out. We received 2 quotes and then awarded it to James Lathem.
CEMETERY	<ul style="list-style-type: none"> • PW Cut Trees and Brush along road and fence area and used chipper to clean everything up • PW Received 2 quotes for a load of top soil, had it delivered to cemetery • PW Removed Whispering Pines sign, pressure washed it and repainted letters then reinstalled it. Looks great. PW also repaired and painted bench that was there • PW helped re level headstones • PW had 2 Burials • PW marked lots for headstones to be installed
BUDGET (Operations 2019)	<ul style="list-style-type: none"> •