

Good Afternoon Lori,

Please see the responses to the Non Compliance Items with Required Actions from the 2020 Inspection of the Temagami North Drinking Water System.

Non Compliance 1.

Required Action: The owner and/or operating authority shall provide written documentation to Provincial Officer/Water Inspector Lori Duquette of the North Bay Office outlining the steps that will be taken to ensure that the maximum rated capacity is not exceeded in the future as a result of increase consumer demand during warm weather.

Response: The owner will work at creating a water conservation by-law for days when temperature is high and/or when there is a risk of the WTP flows exceeding the limit.

Non Compliance 2.

Required Action: The owner and/or operating authority shall provide written documentation to Provincial Officer/Water Inspector Lori Duquette identifying the action that will be taken to ensure the following:

- that the broken chemical dosing pump is replaced; and
- steps are taken to prevent a similar situation from occurring

Response: OCWA, with the Owners approval, is in the process of replacing the existing ALUM pumps with a new chemical panel that includes two new pumps with the functionality of alarming and shutting the system down. There is a plan in place to replace all chemical pumps over the next few years to all have the same functionality preventing the same issue from happening.

Regards,

Rebecca Marshall

Process and Compliance Technician | Ontario Clean Water Agency | North Eastern Ontario Hub | Tel: 705-648-4267 | Fax: 705-567-7974 | Email: rmarshall@ocwa.com



This electronic message (email) contains confidential information only for the use of the Addressee(s) named above. If you are not the intended recipient of the email or the employee or agent responsible for delivering it to the intended recipient(s), you are hereby notified that any dissemination or copying of this email and/or any attachment files is strictly prohibited. If you have received this email in error, please immediately notify the sender and arrange for the return of any and all copies and the permanent deletion of this email and any attachments